Texas Commission on Environmental Quality
Form APD-CERT
Certification of Emission Limits (Page 3)

Emission Rate Data									
FIN	Facility Name	EPN	Point Name	Authorization Type	Authorization Date	Permit or Registration Number (if applicable)	Air Contaminant Name	Maximum Certified Emission Rates	
								Pounds/ Hour	Tons/ Year
UCT EG 1	UTHSCH-UCT	UCT 1	Emergency Generator	106.511	3/14/1997	NA	NOx	9.40E+00	2.43E-01
MSB EG 2	UTHSCH-MSB	MSB 2	Emergency Generator	106.511	3/14/1997	NA	NOx	1.9E+01	9.35E-01
UCT Boiler 1	UTHSCH - UCT	UCT 1B	Boiler - UCT 1	106.183	6/18/1997	NA	NOx	8.20E-01	1.80E+00
UCT Boiler 2	UTHSCH - UCT	UCT 2B	Boiler - UCT 2	106.183	6/18/1997	NA	NOx	8.20E-01	1.80E+00
UCT Boiler 3	UTHSCH - UCT	UCT 3B	Boiler - UCT 3	106.183	6/18/1997	NA	NOx	6.20E-02	2.70E-01
UCT Boiler 4	UTHSCH - UCT	UCT 4B	Boiler - UCT 4	106.183	6/18/1997	NA	NOx	6.20E-02	2.70E-01
IMM Boiler 1	UTHSCH-IMM	IMM 1B	Boiler - IMM 1	106.183	6/18/1997	NA	NOx	7.7E-01	1.7E+00
IMM Boiler 2	UTHSCH-IMM	IMM 2B	Boiler - IMM 2	106.183	6/18/1997	NA	NOx	7.7E-01	1.7E+00
MSB Path 1	UTHSCH - MSB	MSB Path 1	Pathological Incinerator	SE 90	8/30/1996	# 33286	NOx	6.00E-02	2.60E-01
MSB Path 2	UTHSCH - MSB	MSB Path 2	Pathological Incinerator	SE 90	8/30/1996	# 33286	NOx	4.00E-02	1.80E-01

Emissions Totals:	see attached page

Attach additional pages if needed